



Dreams Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

PPS

Lab# 242

Customer

Facility Name: *Obama High School*

Address: *515 N. Highland Ave*
Pittsburgh, PA 15206

Matrix: *Recreational Water*

Source Type: *Pool Shallow*

Sample Collection

Date: *5/4/26*
Time: *8:51 AM*
Method: *Grab*

Sample Final Analysis

Date: *5/7/26*
Time: *10:00 AM*
Analyst: *AS*

Accredited Analysis	Results	Rating	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	A	5/5/26	9:55 AM	AS	SM 9222G
Total coliforms:	0/100mls	A	5/5/26	9:55 AM	AS	SM 9222B
Standard plate count:	0/ml	A	5/4/26	5:00 PM	SL	SM 9215B

Field Analysis	Results	Rating	Date/Time		Analyst	Method
pH:	7.7 SU	B	5/4/26	8:51 AM	MM	DPD
Chlorine:	2.0 mg/l	B	5/4/26	8:51 AM	MM	DPD
Turbidity:	1 NTU	A	5/4/26	8:51 AM	MM	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)