Dreams Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

PPS

Lab# 337

Customer

Facility Name: *Westinghouse H.S*

Address: *1101 Murtland Ave*
Pittsburgh, PA 15208

Matrix: *Recreational Water*

Source Type: *Pool Shallow*

Sample Collection

Date: *3/23/26*
Time: 11:04 AM
Method: *Grab*

Sample Final Analysis

Date: *3/26/26*
Time: *11:30 AM*
Analyst: *AS*

Accredited Analysis	Results	Rating	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	A	3/24/26	11:00 AM	JC	SM 9222G
Total coliforms:	0/100mls	A	3/24/26	11:00 AM	JC	SM 9222B
Standard plate count:	0/ml	A	3/23/26	5:00 PM	SL	SM 9215B

Field Analysis	Results	Rating	Date/Time		Analyst	Method
pH:	7.6 SU	A	3/23/26	11:04 AM	MM	DPD
Chlorine:	2.0 mg/l	B	3/23/26	11:04 AM	MM	DPD
Turbidity:	1 NTU	A	3/23/26	11:04 AM	MM	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor