



Dreams Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

PPS

Lab# 337

Customer

Facility Name: Westinghouse H.S
Address: 1101 Murtland Ave
Pittsburgh, PA 15208

Matrix: Recreational Water

Source Type: Pool Shallow

Sample Collection

Date: 5/26/26
Time: 12:15 PM
Method: Grab

Sample Final Analysis

Date: 5/28/26
Time: 11:30 AM
Analyst: AS

Accredited Analysis	Results	Rating	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	A	5/27/26	11:00 AM	AH	SM 9222G
Total coliforms:	0/100mls	A	5/27/26	11:00 AM	AH	SM 9222B
Standard plate count:	0/ml	A	5/26/26	4:00 PM	AH	SM 9215B

Field Analysis	Results	Rating	Date/Time		Analyst	Method
pH:	7.6 SU	A	5/26/26	12:15 PM	JT	DPD
Chlorine:	3.0 mg/l	A	5/26/26	12:15 PM	JT	DPD
Turbidity:	1 NTU	A	5/26/26	12:15 PM	JT	Visual

Sample comments

Andre Smith

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)