



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

Service

Lab# 425

Customer

Facility Name: Chatham University
Address: 1 Woodland Rd.
Pittsburgh, PA 15232

Sample Collection

Date: 8/10/26
Time: 10:10 AM
Method: Grab

Sample Final Analysis

Date: 8/13/26
Time: 9:00 AM
Analyst: AS

Matrix: Recreational Water
Source Type: Pool Shallow

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/11/26	8:30 AM	MD	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/11/26	8:30 AM	MD	SM 9222B
Standard plate count:	0/ml	200/ml	8/10/26	3:28 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.5 SU	7.2 - 7.8 SU	8/10/26	10:10 AM	MB	DPD
Chlorine:	4.0 mg/l	1.0 - 5.0 mg/l	8/10/26	10:10 AM	MB	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/10/26	10:10 AM	MB	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor