



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-16

Lab# 029

Customer

Facility Name: *Fairfield Inn*

Address: *451 Racetrack Rd.*
Washington, PA 15301

Matrix: *Recreational Water*

Source Type: *Pool*

Sample Collection

Date: *8/11/26*

Time: *1:25 PM*

Method: *Grab*

Sample Final Analysis

Date: *8/14/26*

Time: *10:30 AM*

Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/12/26	10:00 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/12/26	10:00 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	8/11/26	5:10 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.0 SU	7.2 - 7.8 SU	8/11/26	1:25 PM	EB	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	8/11/26	1:25 PM	EB	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/11/26	1:25 PM	EB	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor