



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

Service

Lab# 2250

Customer

Facility Name: Hidden Ridge
Address: 1000 Hidden Ridge Ct.
South Park, PA 15129

Sample Collection

Date: 8/11/26
Time: 1:20 PM
Method: Grab

Matrix: Recreational Water

Sample Final Analysis

Date: 8/14/26
Time: 10:30 AM
Analyst: AS

Source Type: Pool

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/12/26	10:00 AM	MD	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/12/26	10:00 AM	MD	SM 9222B
Standard plate count:	0/ml	200/ml	8/11/26	5:45 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	8/11/26	1:20 PM	AV	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	8/11/26	1:20 PM	AV	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/11/26	1:20 PM	AV	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor