



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-12

Lab# 2304

Customer

Facility Name: *Kennywood Park*

Address: *4800 Kennywood Blvd.
West Mifflin, PA 15122*

Matrix: *Recreational Water*

Source Type: *PGH Plunge*

Sample Collection

Date: *8/10/26*

Time: *1:40 PM*

Method: *Grab*

Sample Final Analysis

Date: *8/13/26*

Time: *11:30 AM*

Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/11/26	11:00 AM	MD	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/11/26	11:00 AM	MD	SM 9222B
Standard plate count:	0/ml	200/ml	8/10/26	7:00 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	8/10/26	1:40 PM	AV	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	8/10/26	1:40 PM	AV	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/10/26	1:40 PM	AV	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)