



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-10

Lab# 2445

Customer

Facility Name: Riverview Childrens

Address: 655 Sylvan Way
Verona, PA 15147

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 8/10/26

Time: 8:10 AM

Method: Grab

Sample Final Analysis

Date: 8/13/26

Time: 9:30 AM

Analyst: 1/0/00

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/11/26	9:00 AM	MD	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/11/26	9:00 AM	MD	SM 9222B
Standard plate count:	5700/ml	200/ml	8/10/26	3:40 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	8/10/26	8:10 AM	LL	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	8/10/26	8:10 AM	LL	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/10/26	8:10 AM	LL	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor