



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**E-14**

**Lab# 474**

**Customer**

Facility Name: Summit Athletic Club

Address: 2900 Plane Rd.  
Altoona, PA 16617

Matrix: Recreational Water

Source Type: Spa

**Sample Collection**

Date: 8/10/26

Time: 2:00 PM

Method: Grab

**Sample Final Analysis**

Date: 8/13/26

Time: 11:00 AM

Analyst: AS

| Accredited Analysis   | Results  | Reporting limit | Incubation Date/Time | Analyst | Method   |
|-----------------------|----------|-----------------|----------------------|---------|----------|
| Escherichia Coli:     | Absent   | Absent          | 8/11/26 10:30 AM     | MD      | SM 9222G |
| Total coliforms:      | 0/100mls | 2/100mls        | 8/11/26 10:30 AM     | MD      | SM 9222B |
| Standard plate count: | 0/ml     | 200/ml          | 8/10/26 6:00 PM      | SL      | SM 9215B |
| Additional Analysis   | Results  | Reporting limit | Incubation Date/Time | Analyst | Method   |
| Fecal Streptococcus   | 0/100mls | 2/100mls        | 8/11/26 12:30 PM     | MD      | SM 9230C |
| Field Analysis        | Results  | Reporting limit | Date/Time            | Analyst | Method   |
| pH:                   | 7.4 SU   | 7.2 - 7.8 SU    | 8/10/26 2:00 PM      | DNP     | DPD      |
| Chlorine:             | 7.5 mg/l | 1.0 - 5.0 mg/l  | 8/10/26 2:00 PM      | DNP     | DPD      |
| Turbidity:            | 1 NTU    | 1 - 2 NTU       | 8/10/26 2:00 PM      | DNP     | Visual   |

**Sample comments**

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)