



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-15

Lab# 2803

Customer

Facility Name: Villas at Spring Valley

Address: 100 Spring Valley Dr.
Zelienople, PA 16063

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 8/12/26

Time: 11:15 AM

Method: Grab

Sample Final Analysis

Date: 8/15/26

Time: 9:00 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/13/26	8:30 AM	MD	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/13/26	8:30 AM	MD	SM 9222B
Standard plate count:	0/ml	200/ml	8/12/26	6:00 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	8/12/26	11:15 AM	EG	DPD
Chlorine:	7.5 mg/l	1.0 - 5.0 mg/l	8/12/26	11:15 AM	EG	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/12/26	11:15 AM	EG	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)