



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

W-12

Lab# 2787

Customer

Facility Name: Woodland Swim Club

Address: 526 Woodland Rd.
Edgeworth, PA 15143

Matrix: Recreational Water

Source Type: Deep End

Sample Collection

Date: 8/10/26

Time: 3:20 PM

Method: Grab

Sample Final Analysis

Date: 8/13/26

Time: 11:00 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/11/26	10:30 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/11/26	10:30 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	8/10/26	6:00 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	8/10/26	3:20 PM	EB	DPD
Chlorine:	10.0 mg/l	1.0 - 5.0 mg/l	8/10/26	3:20 PM	EB	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/10/26	3:20 PM	EB	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)