



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 4

Lab# 2804

Customer *American Pools Management*
3261 Babcock Blvd.
Pittsburgh, PA 15237

Facility Name: *The Max*

Address: *2939 Smallman St.*
Pittsburgh, PA, 15201

Sample Collection

Date: *8/12/26*
Time: *9:10 AM*
Method: *Grab*

Matrix: *Recreational Water*

Source Type: *Pool*

Sample Final Analysis

Date: *8/15/26*
Time: *10:00 AM*
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/13/26	9:30 AM	MD	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/13/26	9:30 AM	MD	SM 9222B
Standard plate count:	0/ml	200/ml	8/12/26	6:00 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	8/12/26	9:10 AM	JB	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	8/12/26	9:10 AM	JB	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/12/26	9:10 AM	JB	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor