



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**APM 3**

**Lab# 2818**

**Customer**      *American Pools Management*  
*3261 Babcock Blvd.*  
*Pittsburgh, PA 15237*

*Facility Name:*      *Mercer*

*Address:*      *2558 Railroad Street.*  
*Pittsburgh, PA 15222*

*Matrix:*      *Recreational Water*

*Source Type:*      *Pool*

**Sample Collection**

*Date:*      *8/12/26*  
*Time:*      *3:15 PM*  
*Method:*      *Grab*

**Sample Final Analysis**

*Date:*      *8/15/26*  
*Time:*      *9:00 AM*  
*Analyst:*      *AS*

| <b>Accredited Analysis</b> | <b>Results</b> | <b>Reporting limit</b> | <b>Incubation Date/Time</b> |         | <b>Analyst</b> | <b>Method</b> |
|----------------------------|----------------|------------------------|-----------------------------|---------|----------------|---------------|
| Escherichia Coli:          | Absent         | Absent                 | 8/13/26                     | 8:50 AM | AH             | SM 9222G      |
| Total coliforms:           | 0/100mls       | 2/100mls               | 8/13/26                     | 8:50 AM | AH             | SM 9222B      |
| Standard plate count:      | 0/ml           | 200/ml                 | 8/12/26                     | 6:00 PM | SL             | SM 9215B      |

| <b>Field Analysis</b> | <b>Results</b> | <b>Reporting limit</b> | <b>Date/Time</b> |         | <b>Analyst</b> | <b>Method</b> |
|-----------------------|----------------|------------------------|------------------|---------|----------------|---------------|
| pH:                   | 7.0 SU         | 7.2 - 7.8 SU           | 8/12/26          | 3:15 PM | JB             | DPD           |
| Chlorine:             | 5.0 mg/l       | 1.0 - 5.0 mg/l         | 8/12/26          | 3:15 PM | JB             | DPD           |
| Turbidity:            | 1 NTU          | 1 - 2 NTU              | 8/12/26          | 3:15 PM | JB             | Visual        |

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor