



1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

CP

Lab# 2028

Customer

Facility Name: Banksville

Address: 1461 Crane Ave.
Pittsburgh, PA 15220

Sample Collection

Date: 8/10/26
Time: 12:40 PM
Method: Grab

Sample Final Analysis

Date: 8/13/26
Time: 9:30 AM
Analyst: AS

Matrix: Recreational Water

Source Type: Deep End

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/11/26	9:00 AM	MD	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/11/26	9:00 AM	MD	SM 9222B
Standard plate count:	0/ml	200/ml	8/11/26	3:40 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	8/10/26	12:40 PM	WB	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	8/10/26	12:40 PM	WB	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/10/26	12:40 PM	WB	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)