



1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

CP

Lab# 2359

Customer

Facility Name: Moore
Address: 1801 Pioneer Ave.
Pittsburgh, PA 15226

Sample Collection

Date: 8/10/26
Time: 12:00 PM
Method: Grab

Matrix: Recreational Water

Source Type: Deep End

Sample Final Analysis

Date: 8/13/26
Time: 9:30 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/11/26	9:20 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/11/26	9:20 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	8/10/26	5:00 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	8/10/26	12:00 PM	WB	DPD
Chlorine:	3.5 mg/l	1.0 - 5.0 mg/l	8/10/26	12:00 PM	WB	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/10/26	12:00 PM	WB	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)