Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-2

Lab# 033

Customer

Facility Name: *Candlewood Suites*

Address: *20036 Oak Tree Place*
Cranberry, PA 16066

Matrix: *Recreational Water*

Source Type: *Pool*

Sample Collection

Date: *3/5/26*
Time: 12:26 PM
Method: *Grab*

Sample Final Analysis

Date: *3/7/26*
Time: *12:00 PM*
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	3/5/26	5:10 PM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	3/5/26	5:10 PM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	3/5/26	4:10 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	3/5/26	12:26 PM	MM	DPD
Chlorine:	4.0 mg/l	1.0 - 5.0 mg/l	3/5/26	12:26 PM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	3/5/26	12:26 PM	MM	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor