# Dream Pools and Spas
## 1105 Washington Blvd
## Pittsburgh, Pennsylvania 15206
## (412) 661- 7665
## Laboratory Analysis Report

**Lab ID No. 02-04041**

**S-2**

***Lab# 489***

**Customer**

*Facility Name:* *Center for Fitness and Health*

*Address:* *800 Plaza Dr. Suite 100*
*Bell Vernon. Pa 15012*

*Matrix:* *Recreational Water*

*Source Type:* *Lap Pool*

**Sample Collection**

*Date:* *9/29/25*
*Time:* 10:50 AM
*Method:* *Grab*

**Sample Final Analysis**

*Date:* *10/2/25*
*Time:* *10:30 AM*
*Analyst:* *AS*

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|---|---|---|---|---|---|---|
| Escherichia Coli: | Absent | Absent | 9/30/25 | 10:10 AM | SL | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 9/30/25 | 10:10 AM | SL | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 9/29/25 | 5:25 PM | SL | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|---|---|---|---|---|---|---|
| pH: | 7.4 SU | 7.2 - 7.8 SU | 9/29/25 | 10:50 AM | SH | DPD |
| Chlorine: | 3.0 mg/l | 1.0 - 5.0 mg/l | 9/29/25 | 10:50 AM | SH | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 9/29/25 | 10:50 AM | SH | Visual |

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor