# Dream Pools and Spas

Lab ID No. 02-04041

Andre Smith, Lead Supervisor

**1105 Washington Blvd**
**Pittsburgh, Pennsylvania 15206**
**(412) 661- 7665**

## Laboratory Analysis Report

**E-1**

***Lab# 454***

[redacted]

| ***Customer*** | | ***Sample Collection*** | |
|---|---|---|---|
| *Facility Name:* | *Hampton Inn* | *Date:* | *3/10/26* |
| | | *Time:* | 11:10 AM |
| *Address:* | *3000 Mosside Blvd.*<br>*Monroeville, PA 15146* | *Method:* | *Grab* |
| | | ***Sample Final Analysis*** | |
| *Matrix:* | *Recreational Water* | *Date:* | *3/13/26* |
| | | *Time:* | *10:30 AM* |
| *Source Type:* | *Pool* | *Analyst:* | *AS* |

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|---|---|---|---|---|---|---|
| Escherichia Coli: | Absent | Absent | 3/11/26 | 10:00 AM | JC | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 3/11/26 | 10:00 AM | JC | SM 9222B |
| Standard plate count: | 570/ml | 200/ml | 3/10/26 | 5:20 PM | SL | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|---|---|---|---|---|---|---|
| pH: | 7.4 SU | 7.2 - 7.8 SU | 3/10/26 | 11:10 AM | SH | DPD |
| Chlorine: | 0.0 mg/l | 1.0 - 5.0 mg/l | 3/10/26 | 11:10 AM | SH | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 3/10/26 | 11:10 AM | SH | Visual |

**Sample comments**

Andre Smith

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)