Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E-2

Lab# 498

[redacted]

Customer		***Sample Collection***	
Facility Name:	*Seven Springs Resort*	*Date:*	*9/15/25*
		Time:	10:35 AM
Address:	*777 Waterwheel Dr.* *Champion, PA 15622*	*Method:*	*Grab*
		Sample Final Analysis	
Matrix:	*Recreational Water*	*Date:*	*9/18/25*
		Time:	*9:00 AM*
Source Type:	*Splash Pad*	*Analyst:*	*AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	9/16/25	9:30 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	9/16/25	9:30 AM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	9/15/25	3:30 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	9/15/25	10:35 AM	JC	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	9/15/25	10:35 AM	JC	DPD
Turbidity:	1 NTU	1 - 2 NTU	9/15/25	10:35 AM	JC	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor