Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

C-1

Lab# 504

[redacted]

Customer		***Sample Collection***	
Facility Name:	*University of Pgh Rec and Wellness*	*Date:*	*12/23/25*
		Time:	9:56 AM
Address:	*3719 Terrace St,*	*Method:*	*Grab*
	Pittsburgh, PA 15213		
		Sample Final Analysis	
Matrix:	*Recreational Water*	*Date:*	*12/26/25*
		Time:	*10:30 AM*
Source Type:	*Spa*	*Analyst:*	*AS*

Accredited Analysis	**Results**	**Reporting limit**	**Incubation Date/Time**		**Analyst**	**Method**
Escherichia Coli:	Absent	Absent	12/24/25	10:00 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/24/25	10:00 AM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	12/23/25	4:20 PM	JC	SM 9215B

Additional Analysis	**Results**	**Reporting limit**	**Incubation Date/Time**		**Analyst**	**Method**
Fecal Streptococcus	0/100mls	2/100mls	12/24/25	12:00 PM	JC	SM 9230C

Field Analysis	**Results**	**Reporting limit**	**Date/Time**		**Analyst**	**Method**
pH:	7.4 SU	7.2 - 7.8 SU	12/23/25	9:56 AM	GR	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	12/23/25	9:56 AM	GR	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/23/25	9:56 AM	GR	Visual

Sample comments

Andre Smith

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)