Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

Service

Lab# ***313***

Customer

Facility Name:	*UPMC Sports Rehab - Cranberry*
Address:	*8000 Cranberry Springs Drive* *Cranberry Township, PA 16066*
Matrix:	*Recreational Water*
Source Type:	*Spa*

Sample Collection

Date:	*3/10/26*
Time:	11:30 AM
Method:	*Grab*

Sample Final Analysis

Date:	*3/13/26*
Time:	*11:30 AM*
Analyst:	*AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	3/11/26	11:00 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	3/11/26	11:00 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	3/10/26	5:20 PM	SL	SM 9215B

Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	3/11/26	11:40 AM	JC	SM 9230C

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	3/10/26	11:30 AM	JR	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	3/10/26	11:30 AM	JR	DPD
Turbidity:	2 NTU	1 - 2 NTU	3/10/26	11:30 AM	JR	Visual

Sample comments

Andre Smith

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor