



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 3

Lab# 2786

Customer *American Pools Management*
3261 Babcock Blvd.
Pittsburgh, PA 15237

Facility Name: *Preserve @ Peter's Twp*
Address: *200 Kerry Ct.*
McMurray, PA 15317

Sample Collection

Date: *6/25/25*
Time: *11:42 AM*
Method: *Grab*

Matrix: *Recreational Water*
Source Type: *Pool*

Sample Final Analysis

Date: *6/27/25*
Time: *4:30 PM*
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/25/25	5:40 PM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/25/25	5:40 PM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/25/25	5:40 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	6/25/25	11:42 AM	AF	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	6/25/25	11:42 AM	AF	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/25/25	11:42 AM	AF	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 3

Lab# 2786

Customer *American Pools Management*
3261 Babcock Blvd.
Pittsburgh, PA 15237

Facility Name: *Preserve @ Peter's Twp*
Address: *200 Kerry Ct.*
McMurray, PA 15317

Sample Collection

Date: *6/25/25*
Time: *11:42 AM*
Method: *Grab*

Matrix: *Recreational Water*
Source Type: *Pool*

Sample Final Analysis

Date: *6/27/25*
Time: *4:30 PM*
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/25/25	5:40 PM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/25/25	5:40 PM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/25/25	5:40 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	6/25/25	11:42 AM	AF	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	6/25/25	11:42 AM	AF	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/25/25	11:42 AM	AF	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor