Lab ID No. 02-04041

Dreams Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

PPS

Lab# 213

Customer

Facility Name: *Langley High School*

Address: *2940 Sheradan Blvd.*
Pittsburgh, PA 15204

Matrix: *Recreational Water*

Source Type: *Pool Shallow*

Sample Collection

Date: *2/23/26*
Time: 8:52 AM
Method: *Grab*

Sample Final Analysis

Date: *2/25/26*
Time: *11:00 AM*
Analyst: *AS*

Accredited Analysis	Results	Rating	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	A	2/24/26	10:30 AM	JC	SM 9222G
Total coliforms:	0/100mls	A	2/24/26	10:30 AM	JC	SM 9222B
Standard plate count:	0/ml	A	2/23/26	5:19 PM	SL	SM 9215B

Field Analysis	Results	Rating	Date/Time		Analyst	Method
pH:	7.6 SU	A	2/23/26	8:52 AM	MM	DPD
Chlorine:	3.0 mg/l	A	2/23/26	8:52 AM	MM	DPD
Turbidity:	1 NTU	A	2/23/26	8:52 AM	MM	Visual

Sample comments

Andre Smith

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)