Lab ID No. 02-04041
W-2

Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665

Lab# 089

Laboratory Analysis Report

Customer

Facility Name: *Donaldson Elementary*

Address: *600 Donaldson Rd.*
Oakdale, PA 15071-3708

Matrix: *Recreational Water*

Source Type: *Pool*

Sample Collection

Date: *3/4/26*
Time: #REF!
Method: *Grab*

Sample Final Analysis

Date: *3/6/26*
Time: *10:00 AM*
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	3/5/26	9:30 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	3/5/26	9:30 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	3/4/26	3:50 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	3/4/26	12:36 PM	SL	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	3/4/26	12:36 PM	SL	DPD
Turbidity:	1 NTU	1 - 2 NTU	3/4/26	12:36 PM	SL	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor