Lab ID No. 02-04041

Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

APM

Lab# 326

Customer		***Sample Collection***	
Facility Name:	*Virginia Mansions*	*Date:*	*3/30/26*
		Time:	9:38 AM
Address:	*2120 Greentree Rd.* *Pittsburgh, PA 15220*	*Method:*	*Grab*
		Sample Final Analysis	
Matrix:	*Recreational Water*	*Date:*	*4/2/26*
		Time:	*12:30 PM*
Source Type:	*Spa*	*Analyst:*	*AS*

Accredited Analysis	**Results**	**Reporting limit**	**Incubation Date/Time**		**Analyst**	**Method**
Escherichia Coli:	Absent	Absent	3/31/26	12:00 PM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	3/31/26	12:00 PM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	3/30/26	5:30 PM	AS	SM 9215B

Additional Analysis	**Results**	**Reporting limit**	**Incubation Date/Time**		**Analyst**	**Method**
Fecal Streptococcus	0/100mls	2/100mls	3/31/26	1:00 PM	SL	SM 9230C

Field Analysis	**Results**	**Reporting limit**	**Date/Time**		**Analyst**	**Method**
pH:	8.0 SU	7.2 - 7.8 SU	3/30/26	9:38 AM	MM	DPD
Chlorine:	10.0 mg/l	1.0 - 5.0 mg/l	3/30/26	9:38 AM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	3/30/26	9:38 AM	MM	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor