



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041
N-17

Lab# 2012

Customer

Facility Name: Alameda Park
Address: 184 Alameda Park Road
Butler, PA 16001

Sample Collection

Date: 8/5/26
Time: 4:02 PM
Method: Grab

Sample Final Analysis

Date: 8/8/26
Time: 10:30 AM
Analyst: AS

Matrix: Recreational Water
Source Type: Spray Pad

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/6/26	10:20 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/6/26	10:20 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	8/5/26	6:15 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	8/5/26	4:02 PM	MM	DPD
Chlorine:	10.0 mg/l	1.0 - 5.0 mg/l	8/5/26	4:02 PM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/5/26	4:02 PM	MM	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)