



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-14

Lab# 464

Customer

Facility Name: *Big Blue Swim School*

Address: *20412 US Rt19*
Cranberry, PA 16066

Matrix: *Recreational Water*

Source Type: *Pool*

Sample Collection

Date: *8/4/26*

Time: *2:20 PM*

Method: *Grab*

Sample Final Analysis

Date: *8/7/26*

Time: *10:00 AM*

Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	8/5/26 9:30 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/5/26 9:30 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	8/4/26 3:55 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	8/4/26 2:20 PM	EG	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	8/4/26 2:20 PM	EG	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/4/26 2:20 PM	EG	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor