



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041
W-13

Lab# 093

Customer

Facility Name: Doubletree Hotel
Address: 8402 University Blvd.
Moon Township, PA 15108

Sample Collection

Date: 8/3/26
Time: 7:48 AM
Method: Grab

Matrix: Recreational Water

Sample Final Analysis

Date: 8/6/26
Time: 11:30 AM
Analyst: AS

Source Type: Pool

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/4/26	11:20 AM	MD	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/4/26	11:20 AM	MD	SM 9222B
Standard plate count:	0/ml	200/ml	8/3/26	7:00 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	8/3/26	7:48 AM	AMH	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	8/3/26	7:48 AM	AMH	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/3/26	7:48 AM	AMH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor