



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-17

Lab# 390

Customer

Facility Name: *Fairfield Inn & Suites*
Address: *1000 University Parkway*
Slippery Rock, PA 16057

Matrix: *Recreational Water*

Source Type: *Spa*

Sample Collection

Date: *8/5/26*
Time: *11:23 AM*
Method: *Grab*

Sample Final Analysis

Date: *8/8/26*
Time: *10:30 AM*
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Escherichia Coli:	Absent	Absent	8/6/26 10:20 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/6/26 10:20 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	8/5/26 6:15 PM	AS	SM 9215B

Additional Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Fecal Streptococcus	0/100mls	2/100mls	8/6/26 10:45 AM	AH	SM 9230C
---------------------	----------	----------	-----------------	----	----------

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
----------------	---------	-----------------	-----------	---------	--------

pH:	7.6 SU	7.2 - 7.8 SU	8/5/26 11:23 AM	MM	DPD
Chlorine:	0.5 mg/l	1.0 - 5.0 mg/l	8/5/26 11:23 AM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/5/26 11:23 AM	MM	Visual

Sample comments

Andre Smith

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)