



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 11

Lab# 441

Customer

Facility Name: Hampton Inn
Address: N. Rachel Dr
New Stanton, PA 15672

Sample Collection

Date: 8/4/26
Time: 8:30 AM
Method: Grab

Sample Final Analysis

Date: 8/7/26
Time: 11:00 AM
Analyst: AS

Matrix: Recreational Water

Source Type: Pool

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/5/26	10:50 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/5/26	10:50 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	8/4/26	5:00 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	8/4/26	8:30 AM	JC	DPD
Chlorine:	7.5 mg/l	1.0 - 5.0 mg/l	8/4/26	8:30 AM	JC	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/4/26	8:30 AM	JC	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor