



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-11

Lab# 146

Customer

Facility Name: Highland School District
Address: 1500 Pacific Ave.
Natrona Heights, PA 15065

Matrix: Recreational Water

Source Type: Deep End

Sample Collection

Date: 8/4/26
Time: 1:35 PM
Method: Grab

Sample Final Analysis

Date: 8/7/26
Time: 10:30 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/5/26	10:15 AM	MD	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/5/26	10:15 AM	MD	SM 9222B
Standard plate count:	0/ml	200/ml	8/4/26	5:00 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	8/4/26	1:35 PM	SH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	8/4/26	1:35 PM	SH	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/4/26	1:35 PM	SH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor