



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 11

Lab# 162

Customer

Facility Name: *Holiday Inn Express*

Address: *3695 State Rd, RT 31*
Donegal, PA 15628

Matrix: *Recreational Water*

Source Type: *Pool*

Sample Collection

Date: *8/4/26*

Time: *9:32 AM*

Method: *Grab*

Sample Final Analysis

Date: *8/7/26*

Time: *11:00 AM*

Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/5/26	10:50 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/5/26	10:50 AM	AH	SM 9222B
Standard plate count:	50/ml	200/ml	8/4/26	5:00 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	8/4/26	9:32 AM	JC	DPD
Chlorine:	7.5 mg/l	1.0 - 5.0 mg/l	8/4/26	9:32 AM	JC	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/4/26	9:32 AM	JC	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)