



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**C-10**

**Lab# 2401**

**Customer**

**Facility Name:** *Pgh Golf Club*  
**Address:** *5280 Northumberland St.*  
*Pittsburgh, PA 15217*

**Sample Collection**

**Date:** *8/4/26*  
**Time:** *1:16 PM*  
**Method:** *Grab*

**Matrix:** *Recreational Water*

**Sample Final Analysis**

**Date:** *8/7/26*  
**Time:** *11:00 AM*  
**Analyst:** *AS*

**Source Type:** *Pool - Deep*

| <b>Accredited Analysis</b> | <b>Results</b> | <b>Reporting limit</b> | <b>Incubation</b> | <b>Date/Time</b> | <b>Analyst</b> | <b>Method</b> |
|----------------------------|----------------|------------------------|-------------------|------------------|----------------|---------------|
| Escherichia Coli:          | Absent         | Absent                 | 8/5/26            | 10:30 AM         | MD             | SM 9222G      |
| Total coliforms:           | 0/100mls       | 2/100mls               | 8/5/26            | 10:30 AM         | MD             | SM 9222B      |
| Standard plate count:      | 0/ml           | 200/ml                 | 8/4/26            | 5:00 PM          | AS             | SM 9215B      |

| Field Analysis | Results  | Reporting limit | Date/Time | Analyst | Method |        |
|----------------|----------|-----------------|-----------|---------|--------|--------|
| pH:            | 7.4 SU   | 7.2 - 7.8 SU    | 8/4/26    | 1:16 PM | JT     | DPD    |
| Chlorine:      | 2.0 mg/l | 1.0 - 5.0 mg/l  | 8/4/26    | 1:16 PM | JT     | DPD    |
| Turbidity:     | 1 NTU    | 1 - 2 NTU       | 8/4/26    | 1:16 PM | JT     | Visual |

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor