



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-13

Lab# 267

Customer

Facility Name: Ringold High School
Address: 1 Ram Drive,
Monongahela, Pa 15063

Sample Collection

Date: 8/3/26
Time: 3:15 PM
Method: Grab

Sample Final Analysis

Date: 8/6/26
Time: 10:30 AM
Analyst: AS

Matrix: Recreational Water

Source Type: Pool

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/4/26	10:25 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/4/26	10:25 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	8/3/26	6:15 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	8/3/26	3:15 PM	SH	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	8/3/26	3:15 PM	SH	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/3/26	3:15 PM	SH	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)