



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

W-12

Lab# 2446

Customer

Facility Name: Robinson Twp Pool
Address: 115 Robinson Pool Lane
McKees Rocks, PA 15136

Matrix: Recreational Water

Source Type: Deep End

Sample Collection

Date: 8/5/26
Time: 12:23 PM
Method: Grab

Sample Final Analysis

Date: 8/8/26
Time: 9:00 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/6/26	9:30 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/6/26	9:30 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	8/5/26	6:15 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	8/5/26	12:23 PM	DW	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	8/5/26	12:23 PM	DW	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/5/26	12:23 PM	DW	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)