



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

1/0/10

Lab# 1/0/10

Customer

Facility Name: Southpointe Golf Club
Address: 360 Southpointe Blvd.
0

Sample Collection

Date: 8/4/26
Time: 3:30 PM
Method: Grab

Sample Final Analysis

Date: 8/7/26
Time: 12:30 PM
Analyst: AS

Matrix: Southpointe Golf Club

Source Type: Pool

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/5/26	12:10 PM	MD	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/5/26	12:10 PM	MD	SM 9222B
Standard plate count:	0/ml	200/ml	8/4/26	7:00 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.0 SU	7.2 - 7.8 SU	8/4/26	3:30 PM	CB	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	8/4/26	3:30 PM	CB	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/4/26	3:30 PM	CB	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor