



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-12

Lab# 2678

Customer

Facility Name: Thomas Jefferson H.S.

Address: 310 Old Clairton Rd.
Clairton, PA 15025

Matrix: Recreational Water

Source Type: Shallow End

Sample Collection

Date: 8/6/26

Time: 11:50 AM

Method: Grab

Sample Final Analysis

Date: 8/8/26

Time: 3:00 PM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/6/26	5:10 PM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/6/26	5:10 PM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	8/6/26	5:10 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	8/6/26	11:50 AM	AV	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	8/6/26	11:50 AM	AV	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/6/26	11:50 AM	AV	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)