



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**E - 11**

**Lab# 2519**

**Customer**

**Facility Name:** Sunridge  
**Address:** 1 Sunridge Dr.  
Champion, PA 15622

**Sample Collection**

**Date:** 8/4/26  
**Time:** 10:53 AM  
**Method:** Grab

**Matrix:** Recreational Water

**Sample Final Analysis**

**Date:** 8/7/26  
**Time:** 11:00 AM  
**Analyst:** AS

**Source Type:** Spa

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | Analyst | Method |
|---------------------|---------|-----------------|----------------------|---------|--------|
|---------------------|---------|-----------------|----------------------|---------|--------|

|                       |          |          |        |          |    |          |
|-----------------------|----------|----------|--------|----------|----|----------|
| Escherichia Coli:     | Absent   | Absent   | 8/5/26 | 10:30 AM | MD | SM 9222G |
| Total coliforms:      | 0/100mls | 2/100mls | 8/5/26 | 10:30 AM | MD | SM 9222B |
| Standard plate count: | 0/ml     | 200/ml   | 8/4/26 | 5:00 PM  | AS | SM 9215B |

| Additional Analysis | Results | Reporting limit | Incubation Date/Time | Analyst | Method |
|---------------------|---------|-----------------|----------------------|---------|--------|
|---------------------|---------|-----------------|----------------------|---------|--------|

|                     |          |          |        |          |    |          |
|---------------------|----------|----------|--------|----------|----|----------|
| Fecal Streptococcus | 0/100mls | 2/100mls | 8/5/26 | 12:00 AM | MD | SM 9230C |
|---------------------|----------|----------|--------|----------|----|----------|

| Field Analysis | Results | Reporting limit | Date/Time | Analyst | Method |
|----------------|---------|-----------------|-----------|---------|--------|
|----------------|---------|-----------------|-----------|---------|--------|

|            |          |                |        |          |    |        |
|------------|----------|----------------|--------|----------|----|--------|
| pH:        | 7.8 SU   | 7.2 - 7.8 SU   | 8/4/26 | 10:53 AM | JC | DPD    |
| Chlorine:  | 1.0 mg/l | 1.0 - 5.0 mg/l | 8/4/26 | 10:53 AM | JC | DPD    |
| Turbidity: | 1 NTU    | 1 - 2 NTU      | 8/4/26 | 10:53 AM | JC | Visual |

**Sample comments**

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)