



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**S-16**

**Lab# 404**

**Customer**

Facility Name: Wilfred R. Cameron Wellness Center

Address: 240 Wellness Way  
Washington, PA 15301

Matrix: Recreational Water

Source Type: Spa

**Sample Collection**

Date: 8/4/26

Time: 1:30 PM

Method: Grab

**Sample Final Analysis**

Date: 8/7/26

Time: 1:00 PM

Analyst: AS

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | Analyst | Method |
|---------------------|---------|-----------------|----------------------|---------|--------|
|---------------------|---------|-----------------|----------------------|---------|--------|

|                   |        |        |        |          |    |          |
|-------------------|--------|--------|--------|----------|----|----------|
| Escherichia Coli: | Absent | Absent | 8/5/26 | 12:50 PM | AH | SM 9222G |
|-------------------|--------|--------|--------|----------|----|----------|

|                  |          |          |        |          |    |          |
|------------------|----------|----------|--------|----------|----|----------|
| Total coliforms: | 0/100mls | 2/100mls | 8/5/26 | 12:50 PM | AH | SM 9222B |
|------------------|----------|----------|--------|----------|----|----------|

|                       |        |        |        |         |    |          |
|-----------------------|--------|--------|--------|---------|----|----------|
| Standard plate count: | 100/ml | 200/ml | 8/4/26 | 7:20 PM | AS | SM 9215B |
|-----------------------|--------|--------|--------|---------|----|----------|

| Additional Analysis | Results | Reporting limit | Incubation Date/Time | Analyst | Method |
|---------------------|---------|-----------------|----------------------|---------|--------|
|---------------------|---------|-----------------|----------------------|---------|--------|

|                     |          |          |        |         |    |          |
|---------------------|----------|----------|--------|---------|----|----------|
| Fecal Streptococcus | 0/100mls | 2/100mls | 8/5/26 | 1:30 PM | MD | SM 9230C |
|---------------------|----------|----------|--------|---------|----|----------|

| Field Analysis | Results | Reporting limit | Date/Time | Analyst | Method |
|----------------|---------|-----------------|-----------|---------|--------|
|----------------|---------|-----------------|-----------|---------|--------|

|     |        |              |        |         |    |     |
|-----|--------|--------------|--------|---------|----|-----|
| pH: | 7.2 SU | 7.2 - 7.8 SU | 8/4/26 | 1:30 PM | JG | DPD |
|-----|--------|--------------|--------|---------|----|-----|

|           |          |                |        |         |    |     |
|-----------|----------|----------------|--------|---------|----|-----|
| Chlorine: | 0.0 mg/l | 1.0 - 5.0 mg/l | 8/4/26 | 1:30 PM | JG | DPD |
|-----------|----------|----------------|--------|---------|----|-----|

|            |       |           |        |         |    |        |
|------------|-------|-----------|--------|---------|----|--------|
| Turbidity: | 1 NTU | 1 - 2 NTU | 8/4/26 | 1:30 PM | JG | Visual |
|------------|-------|-----------|--------|---------|----|--------|

**Sample comments**

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)