



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 12

Lab# 343

Customer

Facility Name: Woodland Hills Senior H.S.

Address: 2550 Greensburg Pike
Pittsburgh, PA 15221

Matrix: Recreational Water

Source Type: Shallow End

Sample Collection

Date: 8/3/26

Time: 11:53 AM

Method: Grab

Sample Final Analysis

Date: 8/6/26

Time: 11:30 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/4/26	11:25 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/4/26	11:25 AM	AH	SM 9222B
Standard plate count:	150/ml	200/ml	8/3/26	7:00 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	8/3/26	11:53 AM	DW	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	8/3/26	11:53 AM	DW	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/3/26	11:53 AM	DW	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)