



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-13

Lab# 360

Customer

Facility Name: YMCA - Mon-Valley

Address: 101 Taylor Run Road
Monongahela, Pa 15063

Matrix: Recreational Water

Source Type: Spa

Sample Collection

Date: 8/3/26
Time: 4:10 PM
Method: Grab

Sample Final Analysis

Date: 8/6/26
Time: 10:30 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/4/26	10:25 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/4/26	10:25 AM	AH	SM 9222B
Standard plate count:	570/ml	200/ml	8/3/26	6:15 PM	AS	SM 9215B
Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	8/4/26	11:40 AM	AH	SM 9230C
Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	8/3/26	4:10 PM	SH	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	8/3/26	4:10 PM	SH	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/3/26	4:10 PM	SH	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)