



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 10

Lab# 2617

Customer

Facility Name: Youghiogheny C.C.
Address: 1901 Greenock Buena Vista Rd.
McKeesport, PA 15135

Sample Collection

Date: 8/4/26
Time: 1:15 PM
Method: Grab

Matrix: Recreational Water

Sample Final Analysis

Date: 8/7/26
Time: 11:00 AM
Analyst: AS

Source Type: Shallow End

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	8/5/26 10:50 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/5/26 10:50 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	8/4/26 5:00 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	8/4/26 1:15 PM	LL	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	8/4/26 1:15 PM	LL	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/4/26 1:15 PM	LL	Visual

Sample comments

Andre Smith

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)