



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 4

Lab# 2738

Customer *American Pools Management*
3261 Babcock Blvd.
Pittsburgh, PA 15237

Facility Name: *South Fayette Twp*
Address: *288 Recreation Rd.*
 Bridgeville, PA 15017

Sample Collection

Date: *8/3/26*
Time: *12:12 PM*
Method: *Grab*

Matrix: *Recreational Water*
Source Type: *Spray Pad*

Sample Final Analysis

Date: *8/6/26*
Time: *10:30 AM*
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/4/26	10:00 AM	MD	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/4/26	10:00 AM	MD	SM 9222B
Standard plate count:	0/ml	200/ml	8/3/26	6:15 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	8/3/26	12:12 PM	JB	DPD
Chlorine:	3.5 mg/l	1.0 - 5.0 mg/l	8/3/26	12:12 PM	JB	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/3/26	12:12 PM	JB	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor