



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 4

Lab# 2724

Customer *American Pools Management*
3261 Babcock Blvd.
Pittsburgh, PA 15237

Facility Name: *Traditions of America Southpointe*
Address: *105 Liberty Blvd.*
Cannonsburg, PA 15317

Sample Collection

Date: 8/4/26
Time: 12:29 PM
Method: *Grab*

Matrix: *Recreational Water*
Source Type: *Spa*

Sample Final Analysis

Date: 8/7/26
Time: 12:30 PM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/5/26	12:20 PM	AH	SM 9222G

Total coliforms:	0/100mls	2/100mls	8/5/26	12:20 PM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	8/4/26	7:00 PM	AS	SM 9215B

Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	8/5/26	1:30 PM	MD	SM 9230C

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	8/4/26	12:29 PM	CB	DPD
Chlorine:	7.5 mg/l	1.0 - 5.0 mg/l	8/4/26	12:29 PM	CB	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/4/26	12:29 PM	CB	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)