



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**APM 4**

**Lab# 2608**

**Customer**      *American Pools Management*  
*3261 Babcock Blvd.*  
*Pittsburgh, PA 15237*

*Facility Name:*      *Yards @ 3 Crossings*

*Address:*      *2645 Railroad St.*  
*Pittsburgh, PA 15222*

*Matrix:*      *Recreational Water*

*Source Type:*      *Spa*

**Sample Collection**

*Date:*      *8/3/26*

*Time:*      *10:10 AM*

*Method:*      *Grab*

**Sample Final Analysis**

*Date:*      *8/6/26*

*Time:*      *11:30 AM*

*Analyst:*      *AS*

| <b>Accredited Analysis</b> | <b>Results</b> | <b>Reporting limit</b> | <b>Incubation Date/Time</b> |          | <b>Analyst</b> | <b>Method</b> |
|----------------------------|----------------|------------------------|-----------------------------|----------|----------------|---------------|
| Escherichia Coli:          | Absent         | Absent                 | 8/4/26                      | 11:20 AM | MD             | SM 9222G      |

|                  |          |          |        |          |    |          |
|------------------|----------|----------|--------|----------|----|----------|
| Total coliforms: | 0/100mls | 2/100mls | 8/4/26 | 11:20 AM | MD | SM 9222B |
|------------------|----------|----------|--------|----------|----|----------|

|                       |      |        |        |         |    |          |
|-----------------------|------|--------|--------|---------|----|----------|
| Standard plate count: | 0/ml | 200/ml | 8/3/26 | 7:00 PM | AS | SM 9215B |
|-----------------------|------|--------|--------|---------|----|----------|

| <b>Additional Analysis</b> | <b>Results</b> | <b>Reporting limit</b> | <b>Incubation Date/Time</b> |          | <b>Analyst</b> | <b>Method</b> |
|----------------------------|----------------|------------------------|-----------------------------|----------|----------------|---------------|
| Fecal Streptococcus        | 0/100mls       | 2/100mls               | 8/4/26                      | 11:40 AM | AH             | SM 9230C      |

| <b>Additional Analysis</b> | <b>Results</b> | <b>Reporting limit</b> | <b>Incubation Date/Time</b> |          | <b>Analyst</b> | <b>Method</b> |
|----------------------------|----------------|------------------------|-----------------------------|----------|----------------|---------------|
| pH:                        | 7.9 SU         | 7.2 - 7.8 SU           | 8/3/26                      | 10:10 AM | JG             | DPD           |

|           |          |                |        |          |    |     |
|-----------|----------|----------------|--------|----------|----|-----|
| Chlorine: | 5.0 mg/l | 1.0 - 5.0 mg/l | 8/3/26 | 10:10 AM | JG | DPD |
|-----------|----------|----------------|--------|----------|----|-----|

|            |       |           |        |          |    |        |
|------------|-------|-----------|--------|----------|----|--------|
| Turbidity: | 1 NTU | 1 - 2 NTU | 8/3/26 | 10:10 AM | JG | Visual |
|------------|-------|-----------|--------|----------|----|--------|

**Sample comments**

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)