



Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 1

Lab# 2037

Customer

American Pools Management
3261 Babcock Blvd.
Pittsburgh, PA 15237

Sample Collection

Facility Name: Belmont Ridge

Date: 8/3/26

Address: 1100 Belmont Blvd.

Time: 3:28 PM

Monroeville, PA 15146

Method: Grab

Sample Final Analysis

Matrix: Recreational Water

Date: 8/6/26

Source Type: Pool

Time: 11:30 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/4/26	11:25 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/4/26	11:25 AM	AH	SM 9222B
Standard plate count:	200/ml	200/ml	8/3/26	7:00 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	8/3/26	3:28 PM	DW	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	8/3/26	3:28 PM	DW	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/3/26	3:28 PM	DW	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)