



**Dream Pools And Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**APM 1**

**Lab# 2056**

**Customer**      *American Pools Management*  
*3261 Babcock Blvd.*  
*Pittsburgh, PA 15237*

*Facility Name:*      *Brentwood Borough Pool*

*Address:*      *Park Dr.*  
*Pittsburgh, PA 15227*

*Matrix:*      *Recreational Water*

*Source Type:*      *Deep End*

**Sample Collection**

*Date:*      8/6/26

*Time:*      8:40 AM

*Method:*      *Grab*

**Sample Final Analysis**

*Date:*      8/8/26

*Time:*      3:00 PM

*Analyst:*      AS

| Accredited Analysis   | Results  | Reporting limit | Incubation Date/Time |         | Analyst | Method   |
|-----------------------|----------|-----------------|----------------------|---------|---------|----------|
| Escherichia Coli:     | Absent   | Absent          | 8/6/26               | 5:10 PM | AS      | SM 9222G |
| Total coliforms:      | 0/100mls | 2/100mls        | 8/6/26               | 5:10 PM | AS      | SM 9222B |
| Standard plate count: | 0/ml     | 200/ml          | 8/6/26               | 5:10 PM | AS      | SM 9215B |

| Field Analysis | Results  | Reporting limit | Date/Time |         | Analyst | Method |
|----------------|----------|-----------------|-----------|---------|---------|--------|
| pH:            | 8.0 SU   | 7.2 - 7.8 SU    | 8/6/26    | 8:40 AM | AV      | DPD    |
| Chlorine:      | 7.5 mg/l | 1.0 - 5.0 mg/l  | 8/6/26    | 8:40 AM | AV      | DPD    |
| Turbidity:     | 1 NTU    | 1 - 2 NTU       | 8/6/26    | 8:40 AM | AV      | Visual |

**Sample comments**

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)