



**Dream Pools And Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**APM 1**

**Lab# 2008**

**Customer**      *American Pools Management*  
*3261 Babcock Blvd.*  
*Pittsburgh, PA 15237*

**Facility Name:**      *Adams Pointe*  
**Address:**      *1000 Adams Pointe Blvd.*  
*Mars, PA 16046*

**Sample Collection**

*Date:*      7/30/26  
*Time:*      10:52 AM  
*Method:*      Grab

**Matrix:**      *Recreational Water*  
**Source Type:**      *Sand Pool*

**Sample Final Analysis**

*Date:*      8/1/26  
*Time:*      4:00 PM  
*Analyst:*      AS

| <b>Accredited Analysis</b> | <b>Results</b> | <b>Reporting limit</b> | <b>Incubation Date/Time</b> |          | <b>Analyst</b> | <b>Method</b> |
|----------------------------|----------------|------------------------|-----------------------------|----------|----------------|---------------|
| Escherichia Coli:          | Absent         | Absent                 | 7/30/26                     | 3:45 PM  | SL             | SM 9222G      |
| Total coliforms:           | 0/100mls       | 2/100mls               | 7/30/26                     | 3:45 PM  | SL             | SM 9222B      |
| Standard plate count:      | 0/ml           | 200/ml                 | 7/30/26                     | 3:10 PM  | 0              | SM 9215B      |
| <b>Field Analysis</b>      | <b>Results</b> | <b>Reporting limit</b> | <b>Date/Time</b>            |          | <b>Analyst</b> | <b>Method</b> |
| pH:                        | 7.6 SU         | 7.2 - 7.8 SU           | 7/30/26                     | 10:52 AM | SL             | DPD           |
| Chlorine:                  | 4.0 mg/l       | 1.0 - 5.0 mg/l         | 7/30/26                     | 10:52 AM | SL             | DPD           |
| Turbidity:                 | 1 NTU          | 1 - 2 NTU              | 7/30/26                     | 10:52 AM | SL             | Visual        |

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor