



**Dream Pools And Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**APM 2**

**Lab# 2114**

**Customer**      *American Pools Management*  
*3261 Babcock Blvd.*  
*Pittsburgh, PA 15237*

*Facility Name:*      *Clover Commons*

*Address:*      *600 Cloverview*  
*Plum, PA 15239*

*Matrix:*      *Recreational Water*

*Source Type:*      *Pool*

**Sample Collection**

*Date:*      *8/4/26*

*Time:*      *5:54 PM*

*Method:*      *Grab*

**Sample Final Analysis**

*Date:*      *8/7/26*

*Time:*      *1:00 PM*

*Analyst:*      *AS*

| <b>Accredited Analysis</b> | <b>Results</b> | <b>Reporting limit</b> | <b>Incubation Date/Time</b> |          | <b>Analyst</b> | <b>Method</b> |
|----------------------------|----------------|------------------------|-----------------------------|----------|----------------|---------------|
| Escherichia Coli:          | Absent         | Absent                 | 8/5/26                      | 12:50 PM | AH             | SM 9222G      |
| Total coliforms:           | 0/100mls       | 2/100mls               | 8/5/26                      | 12:50 PM | AH             | SM 9222B      |
| Standard plate count:      | 0/ml           | 200/ml                 | 8/4/26                      | 7:20 PM  | AS             | SM 9215B      |
| <b>Field Analysis</b>      | <b>Results</b> | <b>Reporting limit</b> | <b>Date/Time</b>            |          | <b>Analyst</b> | <b>Method</b> |
| pH:                        | 7.6 SU         | 7.2 - 7.8 SU           | 8/4/26                      | 5:54 PM  | DW             | DPD           |
| Chlorine:                  | 2.0 mg/l       | 1.0 - 5.0 mg/l         | 8/4/26                      | 5:54 PM  | DW             | DPD           |
| Turbidity:                 | 1 NTU          | 1 - 2 NTU              | 8/4/26                      | 5:54 PM  | DW             | Visual        |

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor