



Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 2

Lab# 2129

Customer

American Pools Management
3261 Babcock Blvd.
Pittsburgh, PA 15237

Sample Collection

Facility Name: Community Swim Club
Address: 106 Aqua Drive
Pittsburgh, PA 15238

Date: 7/27/26
Time: 10:35 AM
Method: Grab

Sample Final Analysis

Matrix: Recreational Water
Source Type: Shallow End

Date: 7/30/26
Time: 10:00 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	7/28/26 9:30 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	1/0/00 9:30 AM	AH	SM 9222B
Standard plate count:	200/ml	200/ml	7/27/26 4:00 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	7/27/26 10:35 AM	LL	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	7/27/26 10:35 AM	LL	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/27/26 10:35 AM	LL	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor